Moberly Fire Department Inspection Report

Address:	**Business Name:**
Phone Number:	**Owner/Agent:**
Emergency Contact:	**Emergency Phone:**

An inspection on this date of the premises by the Moberly Fire Department shows the existence of the following violations of the 2012 International Fire Code, which was adopted by The City of Moberly, Ordinance 9026. For the safety of the occupants, you must correct each violation by complying with this order. A re-inspection will be scheduled by this Department no more than ten business days from the date of this inspection to make sure you have complied with the fire code.

		OUTSIDE	**Pass**	**Fail**
304.1		Waste accumulation prohibited.		
505.1		Address provided and readable from the street and alley		
912.3		Sprinkler connection is not obstructed or blocked		
		MEANS OF EGRESS		
703.2.2		Stairwell and all other fire doors shall not be blocked open		
1004.3		Occupant load posted near the main exit (if required)		
1006.1	1011.4	Means of egress must remain illuminated at all times.		
1003.6		Means of egress unobstructed-exit doors must remain unlocked		
		STORAGE AND GENERAL HOUSKEEPING		
304.3.1		Storage of oily rags must be in self-closing metal cabinet		
315.3		All storage shall be neat, orderly and away from heat		
315.3.1		Storage more than 18 inches from sprinkler head		
315.3.1		Storage more than 2 feet from ceiling (no sprinkler)		
2704.2.1		Flammable storage cabinet needed		
5303.5.3		Gas containers, cylinders, and tanks properly secured		
		ELECTRICAL		
605.1		Electrical wiring and/or components need repair		
605.3		At least 30 inches of clearance from electrical equipment		
605.3.1		Circuits marked for proper usage		
605.4		Eliminate use of multi-plug adapters		
605.5		Proper use of extension cords		
605.6		Approved covers for junction boxes and cover plates		
		FIRE SEPARATIONS		
703.1		Fire wall/separations intact with no breaches		
703.2.2		Proper hold open devices		
703.2.3		Closing device operable		
		COMMENTS		

Moberly Fire Department Inspection Report

FIRE EXTINGUISHERS			Pass	Fail
906.6		Fire extinguishers installed in readily accessible and visible location		
906.2		Fire extinguishers inspected monthly, and service annually		
SPRINKLER & FIRE ALARM SYSTEMS				
912.2.2		Approved sign or arrows to indicate location of hidden FDC		
912.3		Clear access to FDC without obstructions		
912.4		Has metal sign with raised letters at least 1" in size above FDC		
912.5		Backflow protection installed		
913.5		Inspect and test fire pump **Date of Test:**		
901.6.1		Inspect and test standpipes **Date of Test:**		
901.4	901.6	Fire protection systems maintained **Date of Test:**		
901.8.1		No tampering with equipment		
HOOD AND DUCT SYSTEMS				
901.6.2		Provide record of inspection and testing of kitchen suppression system		
904.11		Automatic extinguishing system for commercial cooking systems		
609.1	609.2	Commerical kitchen exhaust hood **Date of Test:**		
609.3.2		Hood and duct system is clean (no grease accumulation present)		
609.3.1		Six month inspection of kitchen hood and suppression system		
BOILER AND MECHANICAL ROOM HAZARDS				
605.3.1	509.1	Electrical and Mechanical rooms labeled		
603.5.2		Emergency shut-off to heating units must be present		
603.6		Maintain chimney and heating units in a safe conditions		
703.1		Boiler room door must be self-closing, one hour fire-resistant rated		
EMERGENCY BUILDING SERVICES				
1008.1.9		Panic and fire exits hardware in working order (doors swing out)		
5003.4		SDS sheets on file (when required)		
Knox Box location				

Miscellaneous:

Inspectors Signature **Owner/Agent Signature**

DATE OF RE-INSPECTION: